

## 【門牆耐火試驗爐】

依據規範：CNS 11227、CNS 12514、CNS 14803、CNS 14815

適用範圍：建築物防火門、捲門、窗、隔間牆之防火時效測試。

判定項目：測試構件（門、牆）之遮焰及阻熱性能。

## 【Fire-resistant test furnace on door wall】

Confirmed standard: CNS 11227, CNS 12514, CNS 14803, CNS 14815.

Scope of application: Fire resistance test for determining the fire resistance of various elements of construction, such as: door, shutter door, windows, wall, partition wall, when subjected to standard fire exposure conditions.

Verification: Fire Integrity and Fire Insulation properties of door, shutter door, windows, wall, partition wall.



門牆耐火試驗爐(Fire-resistant test furnace on door wall)